

Declaration of Conformity

| Manufacturer: | DENT Instruments, Inc |
|---------------|-----------------------|
| | 925 SW Emkay Dr |
| | Bend, OR 97702 USA |
| | (541) 388-4774 |

Declares The CE-Marked Product

| Product Models: | CT-CON-1000-X 1000A Clamp on CT |
|-----------------|--|
| Complies With: | Directive 2006/95/EC Low Voltage (LVD) Directive 2011/65/EC Compliance (RoHS) |

Applicable Standard(s):

| Safety: | | UL 61010-1, 2nd Edition, (Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements) CAN/CSA-C22.2 No. 61010-1, 2nd Edition, (Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements) IEC 61010-1:2001 2nd Edition | |
|---------|--------------------|---|--|
| | | | |
| | IEC 61010-1:2001 2 | | |
| RoHS: | EN 50581:2012 | Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances | |

Testing was performed by Intertek Testing Services (Beaverton, OR)

This Declaration is made October 31, 2009 by:

Christenher L. Dent

Christopher L. Dent, President DENT Instruments, Inc